

| ISBE ID | Building ID | Building Description | Sample Date | Sample Time (12 HR Clock) | Collected By | Sample ID Number | Sample Location Description | Fixture Type | Date of Last Use | Time of Last Use (12 HR Clock) | Sample Type | Sample Volume (mL) | Laboratory Name | Analytical Method | Concentration (ug/L) | Reporting Limit (ug/L) | Notes |
|----------|-------------|-----------------------|-------------|---------------------------|--------------|------------------|----------------------------------|------------------------|------------------|--------------------------------|-------------|--------------------|-----------------|-------------------|----------------------|------------------------|-------|
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:33 AM | Mike Burke | 01 | 01 KS by South Cooler | KS - Kitchen Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 4.6 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:34 AM | Mike Burke | 01A | 01A KS Flush by South Cooler | KS - Kitchen Sink | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 2.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:36 AM | Mike Burke | 02 | 02 KS by North Cooler | KS - Kitchen Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 4.4 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:37 AM | Mike Burke | 02A | 02A KS Flush by North Cooler | KS - Kitchen Sink | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 1.3 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:40 AM | Mike Burke | 03 | 03 Island KS | KS - Kitchen Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 6.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:41 AM | Mike Burke | 03A | 03A Island KS Flush | KS - Kitchen Sink | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:46 AM | Mike Burke | 04 | 04 Cafeteria Right DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:48 AM | Mike Burke | 04A | 04A Cafeteria Right DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 1.6 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:47 AM | Mike Burke | 05 | 05 Cafeteria Left DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:52 AM | Mike Burke | 06 | 06 Library DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 6:53 AM | Mike Burke | 06A | 06A Library DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 6.5 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:00 AM | Mike Burke | 07 | 07 Mezzanine DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:01 AM | Mike Burke | 07A | 07A Mezzanine DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:05 AM | Mike Burke | 08 | 08 Nurses S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 6.6 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:06 AM | Mike Burke | 08A | 08A Nurses S Flush | S - Sink | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:11 AM | Mike Burke | 09 | 09 Gym Lobby DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 5.2 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:12 AM | Mike Burke | 09A | 09A Gym Lobby DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 6.6 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:17 AM | Mike Burke | 10 | 10 Room 109 DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.9 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:18 AM | Mike Burke | 10A | 10A Room 109 DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:23 AM | Mike Burke | 11 | 11 Room 110 DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.7 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:24 AM | Mike Burke | 11A | 11A Room 110 DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:33 AM | Mike Burke | 12 | 12 5th Grade North DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 59.1 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:34 AM | Mike Burke | 13 | 13 5th Grade South DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 20.6 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:35 AM | Mike Burke | 13A | 13A 5th Grade South DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 3.8 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:42 AM | Mike Burke | 14 | 14 4th Grade West DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:43 AM | Mike Burke | 14A | 14A 4th Grade West DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:50 AM | Mike Burke | 15 | 15 3rd Grade North DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:51 AM | Mike Burke | 16 | 16 3rd Grade South DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 7.7 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 7:52 AM | Mike Burke | 16A | 16A 3rd Grade South DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:00 AM | Mike Burke | 17 | 17 SE 5th Grade North DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 126 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:01 AM | Mike Burke | 18 | 18 SE 5th Grade South DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 24.8 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:02 AM | Mike Burke | 18A | 18A SE 5th Grade South DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 3.1 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:10 AM | Mike Burke | 19 | 19 1st Grade North DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:11 AM | Mike Burke | 20 | 20 1st Grade South DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:12 AM | Mike Burke | 20A | 20A 1st Grade South DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:19 AM | Mike Burke | 21 | 21 2nd Grade Southeast DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:20 AM | Mike Burke | 22 | 22 2nd Grade Northwest DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:21 AM | Mike Burke | 22A | 22A 2nd Grade Northwest DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:28 AM | Mike Burke | 23 | 23 Pre-K DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:29 AM | Mike Burke | 23A | 23A Pre-K DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:35 AM | Mike Burke | 24 | 24 Pre-K North S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.7 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:36 AM | Mike Burke | 25 | 25 Pre-K South S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.5 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:37 AM | Mike Burke | 25A | 25A Pre-K South S Flush | S - Sink | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | < 1.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:49 AM | Mike Burke | 26 | 26 South K Pod West DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 12.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:50 AM | Mike Burke | 27 | 27 South K Pod West S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 3.1 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:53 AM | Mike Burke | 27A | 27A South K Pod West S Flush | S - Sink | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 2.4 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:51 AM | Mike Burke | 28 | 28 South K Pod East DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.8 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 8:52 AM | Mike Burke | 29 | 29 South K Pod East S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.5 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 9:05 AM | Mike Burke | 30 | 30 North K North DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 4.0 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 9:06 AM | Mike Burke | 31 | 31 North K North S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 2.4 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 9:07 AM | Mike Burke | 32 | 32 North K South DF | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 1.6 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 9:09 AM | Mike Burke | 32A | 32A North K South DF Flush | DF - Drinking Fountain | 8/13/2017 | 4:00 PM | Flush | 250 | TEKLAB | EPA 200.8 | 1.2 | 1.00 | |
| 30030020 | 2003 | Greenville Elementary | 8/14/17 | 9:08 AM | Mike Burke | 33 | 33 North K South S | S - Sink | 8/13/2017 | 4:00 PM | First Draw | 250 | TEKLAB | EPA 200.8 | 3.3 | 1.00 | |

| Column Title | Description |
|--------------------------------|--|
| ISBE ID | References the Region County District Type Schools (RCDS) number provided by schools on the Chain of Custody to the lab. |
| Building ID | A 4-digit numeric code established by the schools to designate the building being sampled. If only one building is present on-campus then it should be designated 0001. A second building, such as an athletic center, would be designated 0002 and so forth for each additional building. |
| Building Description | A brief description of the building sampled. For example, concession stand. |
| Sample Date | The sample date should match the Chain of Custody and should follow month/day/year (MM/DD/YYYY). |
| Sample Time (12 HR Clock) | The sample time should match the Chain of Custody. |
| Collected By | The name or initials of the person who conducted the sampling. |
| Sample ID Number | This number is established by the person conducting the testing and should match the Sample Number on the Chain of Custody |
| Sample Location Description | This description is established by the person conducting the testing and should match Chain of Custody. |
| Fixture Type | The fixture type should be limited to the drop down menu. If "Other" is selected, a description of the fixture type should be referenced in the Notes of Column R. |
| Date of Last Use | The date should follow month/day/year format (MM/DD/YYYY). |
| Time of Last Use (12 HR Clock) | The time is used to verify that sampling comported with the mandated stagnation period of 8 to 18 hours. |
| Sample Type | The sample type should be limited to the drop down menu. |
| Sample Volume (mL) | First draw and flush samples should be collected in a sterile 250 milliliter (mL) container designated for the collection of potable water. |
| Laboratory Name | Testing should be conducted only at Illinois EPA-accredited laboratories. |
| Analytical Method | The analytical method should be limited to the drop down menu. |
| Concentration (ug/L) | Results are to be reported with three significant digits and units of ppb or microgram per liter (µg/L). For example, 5.12 ppb. |
| Reporting Limit (ug/L) | A minimum reporting limit of 2.00 ppb must be used. |
| Notes | Any additional relevant information. |
| Resources | <ul style="list-style-type: none"> • Lead in Water: http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water • Public Act 99-0922: http://www.ilga.gov/legislation/publicacts/99/PDF/099-0922.pdf • US EPA testing methods: https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockkey=P100PHGZ.txt • IEPA Certified Labs: http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index • Sampling Guidance: http://dph.illinois.gov/sites/default/files/publications/sampling-drinking-water-guidance-021617.pdf |