

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (ml)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
30030020	2004	Pocahontas Elementary	8/9/17	6:30 AM	Mike Burke	01	01 Large KS	KS - Kitchen Sink	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	8.5	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:32 AM	Mike Burke	01A	01A Large KS Flush	KS - Kitchen Sink	8/8/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:31 AM	Mike Burke	02	02 Small KS	KS - Kitchen Sink	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	7.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:39 AM	Mike Burke	03	03 Cafeteria Left DF	DF - Drinking Fountain	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:41 AM	Mike Burke	03A	03 Cafeteria Left DF Flush	DF - Drinking Fountain	8/8/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:40 AM	Mike Burke	04	04 Cafeteria Right DF	DF - Drinking Fountain	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:47 AM	Mike Burke	05	05 KRP Classroom (Pre-K) S	S - Sink	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:48 AM	Mike Burke	05A	05A KRP Classroom (Pre-K) S Flush	S - Sink	8/8/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:55 AM	Mike Burke	06	06 Hallway DF by 7th Grade Room	DF - Drinking Fountain	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	4.5	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	6:56 AM	Mike Burke	06A	06A Hallway DF Flush by 7th Grade Room	DF - Drinking Fountain	8/8/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	8.7	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	7:06 AM	Mike Burke	07	07 Hallway Left DF by 4th Grade Room	DF - Drinking Fountain	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	7:07 AM	Mike Burke	08	08 Hallway Right DF by 4th Grade Room	DF - Drinking Fountain	8/8/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2004	Pocahontas Elementary	8/9/17	7:08 AM	Mike Burke	08A	08A Hallway Right DF Flush by 4th Grade Room	DF - Drinking Fountain	8/8/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	< 1.0	1.00	

Column Title	Description
ISBE ID	References the Region County District Type Schools (RCDS) number provided by schools on the Chain of Custody to the lab.
Building ID	A 4-digit numeric code established by the schools to designate the building being sampled. If only one building is present on-campus then it should be designated 0001. A second building, such as an athletic center, would be designated 0002 and so forth for each additional building.
Building Description	A brief description of the building sampled. For example, concession stand.
Sample Date	The sample date should match the Chain of Custody and should follow month/day/year (MM/DD/YYYY).
Sample Time (12 HR Clock)	The sample time should match the Chain of Custody.
Collected By	The name or initials of the person who conducted the sampling.
Sample ID Number	This number is established by the person conducting the testing and should match the Sample Number on the Chain of Custody
Sample Location Description	This description is established by the person conducting the testing and should match Chain of Custody.
Fixture Type	The fixture type should be limited to the drop down menu. If "Other" is selected, a description of the fixture type should be referenced in the Notes of Column R.
Date of Last Use	The date should follow month/day/year format (MM/DD/YYYY).
Time of Last Use (12 HR Clock)	The time is used to verify that sampling comported with the mandated stagnation period of 8 to 18 hours.
Sample Type	The sample type should be limited to the drop down menu.
Sample Volume (mL)	First draw and flush samples should be collected in a sterile 250 milliliter (mL) container designated for the collection of potable water.
Laboratory Name	Testing should be conducted only at Illinois EPA-accredited laboratories.
Analytical Method	The analytical method should be limited to the drop down menu.
Concentration (ug/L)	Results are to be reported with three significant digits and units of ppb or microgram per liter (µg/L). For example, 5.12 ppb.
Reporting Limit (ug/L)	A minimum reporting limit of 2.00 ppb must be used.
Notes	Any additional relevant information.
Resources	<ul style="list-style-type: none"> <li>• Lead in Water: <a href="http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water">http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water</a></li> <li>• Public Act 99-0922: <a href="http://www.ilga.gov/legislation/publicacts/99/PDF/099-0922.pdf">http://www.ilga.gov/legislation/publicacts/99/PDF/099-0922.pdf</a></li> <li>• US EPA testing methods: <a href="https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P100PHGZ.txt">https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P100PHGZ.txt</a></li> <li>• IEPA Certified Labs: <a href="http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index">http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index</a></li> <li>• Sampling Guidance: <a href="http://dph.illinois.gov/sites/default/files/publications/sampling-drinking-water-guidance-021617.pdf">http://dph.illinois.gov/sites/default/files/publications/sampling-drinking-water-guidance-021617.pdf</a></li> </ul>