

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
30030020	2005	Sorento Elementary	8/10/17	6:28 AM	Mike Burke	01	01 Kitchen KS	KS - Kitchen Sink	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	22.7	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:29 AM	Mike Burke	01A	01A Kitchen KS Flush	KS - Kitchen Sink	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	3.8	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:34 AM	Mike Burke	02	02 Right Hallway DF by Cafeteria	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	1.0	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:36 AM	Mike Burke	02A	02A Right Hallway DF Flush by Cafeteria	DF - Drinking Fountain	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	1.1	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:35 AM	Mike Burke	03	03 Left Hallway DF by Cafeteria	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	1.7	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:41 AM	Mike Burke	04	04 LD Room DF	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	55.2	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:43 AM	Mike Burke	04A	04A LD Room DF Flush	DF - Drinking Fountain	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	13.0	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:42 AM	Mike Burke	05	05 LD Room S	S - Sink	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	45.0	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:46 AM	Mike Burke	06	06 Kindergarten S	S - Sink	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	51.8	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:48 AM	Mike Burke	06A	06A Kindergarten S Flush	S - Sink	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	5.6	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:47 AM	Mike Burke	07	07 Kindergarten DF	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	9.1	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:51 AM	Mike Burke	08	08 Nurses S	S - Sink	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	27.4	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:52 AM	Mike Burke	08A	08A Nurses S Flush	S - Sink	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	2.3	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:56 AM	Mike Burke	09	09 Lower Pod West DF	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	8.1	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:58 AM	Mike Burke	09A	09A Lower Pod West DF Flush	DF - Drinking Fountain	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	6.5	1.00	
30030020	2005	Sorento Elementary	8/10/17	6:57 AM	Mike Burke	10	10 Lower Pod East DF	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	8.1	1.00	
30030020	2005	Sorento Elementary	8/10/17	7:05 AM	Mike Burke	11	11 Upper Pod North DF	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	8.0	1.00	
30030020	2005	Sorento Elementary	8/10/17	7:07 AM	Mike Burke	11A	11A Upper Pod North DF Flush	DF - Drinking Fountain	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	2.7	1.00	
30030020	2005	Sorento Elementary	8/10/17	7:06 AM	Mike Burke	12	12 Upper Pod South DF	DF - Drinking Fountain	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	30.0	1.00	
30030020	2005	Sorento Elementary	8/10/17	7:14 AM	Mike Burke	13	13 Pre-K KRP Rm. S	S - Sink	8/9/2017	2:30 PM	First Draw	250	TEKLAB	EPA 200.8	< 1.0	1.00	
30030020	2005	Sorento Elementary	8/10/17	7:15 AM	Mike Burke	13A	13A Pre-K KRP Rm. S Flush	S - Sink	8/9/2017	2:30 PM	Flush	250	TEKLAB	EPA 200.8	< 1.0	1.00	

Column Title	Description
ISBE ID	References the Region County District Type Schools (RCDS) number provided by schools on the Chain of Custody to the lab.
Building ID	A 4-digit numeric code established by the schools to designate the building being sampled. If only one building is present on-campus then it should be designated 0001. A second building, such as an athletic center, would be designated 0002 and so forth for each additional building.
Building Description	A brief description of the building sampled. For example, concession stand.
Sample Date	The sample date should match the Chain of Custody and should follow month/day/year (MM/DD/YYYY).
Sample Time (12 HR Clock)	The sample time should match the Chain of Custody.
Collected By	The name or initials of the person who conducted the sampling.
Sample ID Number	This number is established by the person conducting the testing and should match the Sample Number on the Chain of Custody
Sample Location Description	This description is established by the person conducting the testing and should match Chain of Custody.
Fixture Type	The fixture type should be limited to the drop down menu. If "Other" is selected, a description of the fixture type should be referenced in the Notes of Column R.
Date of Last Use	The date should follow month/day/year format (MM/DD/YYYY).
Time of Last Use (12 HR Clock)	The time is used to verify that sampling comported with the mandated stagnation period of 8 to 18 hours.
Sample Type	The sample type should be limited to the drop down menu.
Sample Volume (mL)	First draw and flush samples should be collected in a sterile 250 milliliter (mL) container designated for the collection of potable water.
Laboratory Name	Testing should be conducted only at Illinois EPA-accredited laboratories.
Analytical Method	The analytical method should be limited to the drop down menu.
Concentration (ug/L)	Results are to be reported with three significant digits and units of ppb or microgram per liter (µg/L). For example, 5.12 ppb.
Reporting Limit (ug/L)	A minimum reporting limit of 2.00 ppb must be used.
Notes	Any additional relevant information.
Resources	<ul style="list-style-type: none"> <li>• Lead in Water: <a href="http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water">http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water</a></li> <li>• Public Act 99-0922: <a href="http://www.ilga.gov/legislation/publicacts/99/PDF/099-0922.pdf">http://www.ilga.gov/legislation/publicacts/99/PDF/099-0922.pdf</a></li> <li>• US EPA testing methods: <a href="https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P100PHGZ.txt">https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P100PHGZ.txt</a></li> <li>• IEPA Certified Labs: <a href="http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index">http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index</a></li> <li>• Sampling Guidance: <a href="http://dph.illinois.gov/sites/default/files/publications/sampling-drinking-water-guidance-021617.pdf">http://dph.illinois.gov/sites/default/files/publications/sampling-drinking-water-guidance-021617.pdf</a></li> </ul>